



06 May 2016

NATURALHOUSECO
9 Trewavas St,
Motueka,
Nelson Bays,
7120
Via email: duncan@naturalhouse.co.nz

To Whom It May Concern

RE: Compatibility of Fireshield 1FR over NATURALHOUSECO™ plant oil based stain.

We can confirm that the Protega laboratory in Sweden reviewed the supplied NATURALHOUSECO™ stain and carried out adhesion tests, including attempting to ignite the product once coated with Fireshield 1FR system.

NATURALHOUSECO™ stain did not have any adverse effects or adhesion issues when used with the Fireshield 1FR system.

If applied in accordance with our application instructions by an approved applicator, timber coated with NATURALHOUSECO™ plant oil based stain, and the Fireshield 1FR system, will achieve a Group 1-S surface finish for compliance purposes.

Please do not hesitate to call or email if you have any questions.

Sincerely,

Matthew Hughes
Business Development Manager
matthew@fireshield.co.nz

Fire Protection Coatings Ltd, exclusive importer of PROTEGA intumescent paints to Australia and New Zealand

FIRE PROTECTION COATINGS LTD, PO Box 19-888, Woolston, Christchurch 8022

E-mail: info@fireshield.co.nz | Tel: 0800 FIRESHIELD / 0800 347 374

fireshield.co.nz